
The comments of this pre-app are preliminary in nature and subject to change based upon the submittal of additional or different information. The Planning Commission or City Council are the final decision making authority of the City, and are not bound by the comments made by the Staff as part of this pre-application.

**ASHLAND PLANNING DIVISION
PRE-APPLICATION CONFERENCE
COMMENT SHEET**
September 2, 2020

SITE: 680 Oak St.
APPLICANT: Rogue for Abel
REQUEST: Type I Variance

PLANNING DIVISION COMMENTS

This pre-application conference is intended to highlight significant issues before the applicant prepares and submits a formal application.

Summary: The proposal requires a variance to driveway spacing. Staff is generally supportive but feels that the site plan will need show additional detail in terms of dimensions from adjacent driveways for a formal application.

The TSP shows Oak to be an avenue, which requires a 100' driveway spacing.

The proposal decreases the nonconformity by increasing the spacing between both the driveway to the north and south.

If approved the existing curb cut would need to be abandoned and restored, and any additional curb cuts along the frontage will be required to be replaced with standard curb.

VARIANCE APPROVAL CRITERIA

A. The approval authority through a Type I or Type II procedure, as applicable, may approve a variance upon finding that it meets all of the following criteria.

1. The variance is necessary because the subject code provision does not account for special or unique physical circumstances of the subject site, such as topography, natural features, adjacent development, or similar circumstances. A legal lot determination may be sufficient evidence of a hardship for purposes of approving a variance.
2. The variance is the minimum necessary to address the special or unique physical circumstances related to the subject site.
3. The proposal's benefits will be greater than any negative impacts on the development of the adjacent uses and will further the purpose and intent of this ordinance and the Comprehensive Plan of the City.
4. The need for the variance is not self-imposed by the applicant or property owner. For example, the variance request does not arise as result of a property line adjustment or land division approval previously granted to the applicant.

B. In granting a variance, the approval authority may impose conditions similar to those provided for conditional uses to protect the best interests of the surrounding property and property owners, the neighborhood, or the City as a whole.

OTHER ORDINANCE REQUIREMENTS: No comments.

OTHER CITY OF ASHLAND DEPARTMENT COMMENTS

BUILDING: No comments at this time. Please contact the Building Division for any building codes-related questions at 541-488-5305.

CONSERVATION: For more information on available water conservation programs, including any available appliance rebates or assistance with landscaping and irrigation system requirements, please contact Water Conservation Specialist Julie Smitherman of Conservation Division at 541-552-2062 or via e-mail to julie.smitherman@ashland.or.us . For information on any financial or technical assistance available for the construction of Earth Advantage/Energy Star buildings, please contact Conservation Analyst/Inspector Dan Cunningham at 541-552-2063 or via e-mail to dan.cunningham@ashland.or.us

ENGINEERING: No comments at this time. Please contact Karl Johnson of the Engineering Division for any Public Works/Engineering information at 541-552-2415 or via e-mail to karl.johnson@ashland.or.us .

FIRE: See attached comments. Please contact Ralph Sartain from the Fire Department for any Fire Department-related information at 541-552-2229 or via e-mail to ralph.sartain@ashland.or.us.

WATER AND SEWER SERVICE: If the project requires additional water services or upgrades to existing services the Ashland Water Department will excavate and install in the city right of way all water services up to and including the meter on domestic and commercial water lines. If a fire line is required, the water department will also only install a stub out to the location where the double detector check assembly complete with a Badger brand cubic foot bypass meter should be placed in a vault external to the building. The vault and the DCDA device housed in it are the responsibility of the property owner and should be placed at the property line. Fees for these installations are paid to the water department and are based on a time and materials quote to the developer or contractor. Meter sizes and fire line diameters will need to be provided to the Water Department at the time of a quote being requested. Please Contact Steve Walker at [541-552-2326](tel:541-552-2326) or (walkers@ashland.or.us) with any questions regarding water utilities.

ELECTRIC SERVICE: Please contact Dave Tygerson in the Electric Department for service requirements and connect fee information at (541) 552-2389 or via e-mail to tygersod@ashland.or.us. Dave will arrange an on-site meeting, and develop a preliminary electrical service plan for the site. Please allow additional time to accommodate scheduling of this on-site meeting and preparing the preliminary plan. Submittals will not be deemed complete without a preliminary approved plan from the Electric Department.

PROCEDURE

Site design review for two or more units is subject to a “Type I” procedure which includes an administrative decision made following public notice and a public comment period. Type I decisions provide an opportunity for appeal to the Planning Commission.

APPLICATION REQUIREMENTS

Submittal Information.

The application is required to include all of the following information.

- a. The information requested on the application form at <http://www.ashland.or.us/Files/Zoning%20Permit%20Application.pdf> .
- b. Plans and exhibits required for the specific approvals sought (see below).
- c. A written statement or letter explaining how the application satisfies each and all of the relevant criteria and standards in sufficient detail (see below).
- d. Information demonstrating compliance with all prior decision(s) and conditions of approval for the subject site, *as applicable*.
- e. The required fee (see below).

The Ashland Land Use Ordinance, which is Chapter 18 of the Municipal Code, is available on-line in its entirety at: <https://ashland.municipal.codes/LandUse>

Written Statements

Please provide two copies of a written statements explaining how the application meets the approval criteria from the sections of the Ashland Municipal Code listed below. These written statements provide the Staff Advisor or Planning Commission with the basis for approval of the application:

- o **Variance AMC 18.5.2.050**

Plans & Exhibits Required

Please provide two sets of exhibits (plans or drawings) addressing the submittal requirements from the sections of the Ashland Municipal Code listed below. These exhibits are used to copy the Planning Commission packets and for notices that are mailed to neighbors. Please provide two copies on paper no larger than 11-inches by 17-inches and reproducible copies that are drawn to a standard architect’s or engineer’s scale.

- o **Plan: AMC 18.5.5.040.B**

PLANNING APPLICATION FEES:

Type I Variance	\$1,092
-----------------	---------

NOTE: Applications are accepted on a first come-first served basis. All applications received are reviewed and must be found to be complete before being processed or scheduled at a Planning Commission meeting. Applications will not be accepted without a complete application form signed by the applicant(s) and property owner(s), all required materials and full payment. Applications are reviewed for completeness in accordance with ORS 227.178.

For further information, please contact:

Aaron Anderson, *Assistant Planner*

City of Ashland, Department of Community Development

Phone: 541-552-2052 or e-mail: aaron.anderson@ashland.or.us

September 2, 2019

Date