

# Water Quality Report

REPORTING YEAR 2021



Paper copies available upon request

En Español : Este Informe contiene informacion importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

You can help conserve water.

Call 541-552-2062 for tips and information.



## The City of Ashland Provides Exceptional Water *for you.*

From snowmelt and rainfall sources to your tap, the City of Ashland reliably delivers the highest quality water possible. Our primary source is Ashland Creek, collected in Reeder Reservoir. We are pleased that all water treated meets and exceeds Oregon Health Authority and EPA water quality regulations. We encourage you to take the time to become familiar with the information contained in this report.

At the City, we are stewards of your water system and work diligently to maintain the best water for your needs.

**Our fresh clean water is a limited resource.** Please follow these guidelines when you use it in your yard.




It is best not to water every day. Less frequent, deep sprinkling will encourage deeper root growth and plants won't become stressed as quickly when the weather is hot.

Adjust your watering schedule throughout the summer to account for current weather conditions. Doing this can significantly reduce the amount of water consumed.



Water between 8:00 p.m. and 6:00 a.m. to avoid losing water to wind and evaporation.



### YOUR VIEWS ARE WELCOMED!

If you would like to learn more about issues affecting your community, City Council meetings are the first and third Tuesdays at 7 P.M. bi-weekly.

#### Contact Information and Resources

**Alistair Andre**  
Water Plant Supervisor  
541-488-6016

**Mike Morrison**  
Public Works Superintendent  
541-552-2325

**Scott Fleury**  
Public Works Director  
541-552-2412

**Vacant Position**  
Water Conservation Specialist  
541-552-2062

**Oregon Health Authority  
Drinking Water Program**  
971-673-0405

**EPA Safe Drinking Hotline**  
800-426-4791

**Forest Land Commission**  
541-552-2066

**Jackson County Health  
Department**  
541-774-8206

**TTY Number  
(hearing impaired)**  
800-735-2900

**City Council meetings**  
541-488-6002  
1st and 3rd Tuesdays at 7:00 pm

**Steve Walker**  
Water Distribution Supervisor  
541-552-2326

**Medford Water  
Commission**  
541-774-2728

**Talent Irrigation District  
Board Meetings**  
541-535-1529

# 2021 Ashland Drinking Water Data

Analyte	Sample Date	Range PPM	Detected PPM	Average PPM	MCL PPM	MCLG PPM	Typical Source
Turbidity	Hourly	0.03 - 0.19	Yes	0.04 NTU	0.3 NTU	0.3 NTU	Soil erosion & stream sediments
Sodium Hypochlorite	Daily	0.20 - 1.51	Yes	0.85	4	4	Treatment additive for disinfection
Coliform Bacteria	Weekly	ND	ND	0	Detected	Absent	Naturally present in the environment
TOC Raw	Monthly	1.80 - 3.44	Yes	2.83	No Limit	N/A	
TOC Finished	Monthly	0.93 - 1.59	Yes	1.25	No Limit	N/A	
Sodium	8/7/2020	11.6	Yes	11.6	No Limit	N/A	Erosion of natural deposits
Fluoride	7/23/2020	ND	ND	0	4	4	Naturally present in the environment
Nitrate		ND	ND	0	10	10	Naturally present in the environment. Also from septic tanks and fertilizers.
Copper	6/14/2020	90th percentile	0.29	0.094	1.3	1.3	Corrosion of plumbing systems
0 of 30 samples collected exceeded action levels.							
Barium	8/7/2020	ND - .005	0.005	0.005	2	2	Erosion of natural deposits

Analyte	Sample Date	Range PPB	Detected PPB	Average PPB	MCL PPB	MCLG PPB	Typical Source
TTHM	Quarterly	2.38 - 42.7	Yes	26.23	80	n/a	By-product of disinfection
HAA5	Quarterly	ND - 35.1	Yes	22.3	60	n/a	
0 of 16 samples collected exceeded action levels. (No Violation)							
Lead	7/23/2020 7/24/2020	90th percentile	2.10	0.96	15	0	Corrosion of plumbing systems
0 of 30 samples collected exceeded action levels.							

The Oregon Health Authority allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old. We sample for a large range of contaminants that are both EPA regulated and unregulated. Additional regulated contaminant results are available on the OHA Drinking Water web site. Additional unregulated contaminant results are available by request from Ashland's Water Quality Department.

## MEDFORD WATER COMMISSION

Analyte	Sample Date	Range PPM	Detected PPM	Average PPM	MCL PPM	MCLG PPM	Typical Source
Turbidity	Hourly	0.04 - 0.45 NTU	Yes	0.06 NTU	95%<0.3 NTU	N/A	Soil erosion & stream sediments
Sodium Hypochlorite	Daily	0.19 - 0.91	Yes	0.68	4	4	Treatment additive for disinfection
Coliform Bacteria	Weekly	ND	ND	0	Detected	Absent	Naturally present in the environment
TOC Finished	Monthly	0.6 - 1.0	Yes	0.81	No Limit	N/A	
Copper	2019	90th percentile	0.8	N/A	1.3	1.3	
<b>Rogue River</b>							
Nickel	2020	0.002	Yes	0.002	N/A	N/A	Corrosion of galvanized pipes;erosion of natural deposits;discharge of metal refineries;runoff from waste batteries and paints.
Barium	2020	0.005	Yes	0.005	2	2	Erosion of natural deposits. Metal refineries. Drilling waste.
Big Butte Springs							
Barium	2020	0.003	Yes	0.003	2	2	

Analyte	Sample Date	Range PPB	Detected PPB	Average PPB	MCL PPB	MCLG PPB	Typical Source
TTHM	Quarterly	ND - 23.8	Yes	13.1	80	n/a	By-product of disinfection
HAA5	Quarterly	ND - 24.4	Yes	9.4	60	n/a	
Lead	2019	90th percentile	0.9	0.511	15	0	Corrosion of plumbing systems

## ROGUE RIVER

Cadmium	2020	0.2	Yes	0.2	5	5	Corrosion of galvanized pipes;erosion of natural deposits;discharge of metal refineries;runoff from waste batteries and paints.
---------	------	-----	-----	-----	---	---	---

## BIG BUTTE SPRINGS

Radon-222 (pCi/L)	2018	88 pCi/L	Yes	N/A	N/A	N/A	Erosion of natural deposits
-------------------	------	----------	-----	-----	-----	-----	-----------------------------

### \*UNIT DESCRIPTIONS:

**AL:** Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**HAA5, HAA6Br, HAA9:** Haloacetic Acids

**MCL:** Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**MCLG:** Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is

no known or expected risk to health. MCLGs allow for a margin of safety.

**mg/L:** Milligrams per liter: One unit (by weight) out of one million of the same unit.

**MRDL:** The highest level of disinfectant allowed in drinking water.

**MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health

**NA:** Not applicable

**ND:** Not Detected.

**NTU:** Nephelometric Turbidity Units.

**pCi/L:** Picocuries per Liter.

**PPB:** Parts Per Billion. One part per billion parts.

**PPM:** (parts per million) One part substance per million parts water (or milligrams per liter)

**TOC:** Total Organic Carbon

**TTHM:** Total Trihalomethanes

## SOURCE WATER ASSESSMENT

A source water assessment is available. The greatest risk of contaminants to Ashland's water is soil sedimentation in the watershed.

### A MESSAGE FROM THE EPA

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants, potential health effects and questions on information in this section can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791) or visiting [www.epa.gov/safewater](http://www.epa.gov/safewater).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections.

These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the EPA's Safe Drinking Water Hotline (1-800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.

The City of Ashland is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. We take steps to eliminate the potential for lead and copper to leach from our pipes and your plumbing by the addition of sodium carbonate.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

**Microbial contaminants,** such as viruses and bacteria, which may come from, septic systems, agricultural livestock operations and wildlife.

**Inorganic contaminants,** such as salts and metals, which can be naturally occurring or result from urban storm runoff, domestic wastewater discharges, mining, or farming.

**Pesticides and herbicides,** which may come from a variety of sources such as agriculture, storm water runoff, and residential uses.

**Organic chemical contaminants,** including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water run-off, and septic systems.

**Radioactive contaminants,** which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

919,800,000

Ashland Drinking Water Plant  
Gallons Treated

0

Talent Irrigation District  
Gallons Pumped

178,100,000

Medford Water Commission  
Gallons Pumped

1,097,900,000

Total Gallons Provided to the City of Ashland